

# PERMIT TO OPERATE

Permit No. TBD  
A/N 504110

## Equipment Description:

STORAGE TANK NO. 791, FIXED CONE ROOF TANK, 117' DIA. X 41' H., 79,000 BBL SHELL CAPACITY, WITH A CLOSEABLE VENT LINE CONNECTION TO THE TERMINAL'S VAPOR RECOVERY SYSTEM.

## Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THE VENT LINE TO THE VAPOR RECOVERY SYSTEM SHALL REMAIN OPEN WHEN THE TANK IS IN SERVICE EXCEPT THAT THE VENT LINE MAY BE CLOSED WHEN THE TANK IS USED TO STORE THE FOLLOWING COMMODITIES:  
  
DIESEL FUEL (INCLUDING BIODIESEL)  
JET A KEROSENE  
  
[RULE 463, 1303(a)(1)-BACT, 1303(b)(2)-OFFSETS, RULE 1401, 40 CFR 63 SUBPART R]
4. THE OPERATOR SHALL KEEP A RECORD OF ALL PRODUCTS STORED IN THIS TANK. THE RECORD SHALL IDENTIFY EACH PRODUCT AND INCLUDE THROUGHPUT, RIED VAPOR PRESSURE, DATES OF STORAGE, AND STATUS OF THE VENT LINE TO THE VAPOR RECOVERY SYSTEM (OPEN OR CLOSED).  
[RULE 463, 1303(a)(1)-BACT, 1303(b)(2)-OFFSETS, RULE 1401, 40 CFR 63 SUBPART R]
5. THE COMBINED THROUGHPUT FOR TANKS 791 AND 797 SHALL NOT EXCEED 50,740,200 GALLONS IN ANY ONE CALENDAR MONTH. THE MAXIMIUMCALENDAR MONTHLY THROUGHPUT FOR PRODUCTS OTHER THAN DIESEL AND JET A KEROSENE SHALL NOT EXCEED:  
  

TANK NO. 791	19,756,800 GALLONS
TANK NO. 797	30, 983, 400 GALLONS

  
[RULE 463, 1303(a)(1)-BACT, 1303(b)(2)-OFFSETS, RULE 1401, 40 CFR 63 SUBPART R]
6. THIS TANK SHALL NOT BE USED TO STORE ORGAINC LIQUIDS WITH A RIED VAPOR PRESSURE GREATER THAN RVP 15 PSI.  
[BACT RULE 1303(B)(2)-OFFSETS]
7. ALL RECORDS REQUIRED BY THE CONDITIONS OF THE IS PERMIT INCLUDING THOSE RECORDS REQUIRED BY RULE 463, SHALL BE MAINTAINED FOR A FIVE YEAR PERIOD AND BE AVAILABLE FOR INSPECTION BY AUTHORIZED DISTRICT PERSONNEL.  
[RULE 463]

**Periodic Monitoring: NONE**

**Emissions and Requirements:**

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 463

VOC: RULE 1149

HAP/TOC: 40 CFR 63 SUBPART R (MAJOR SOURCE)

# PERMIT TO OPERATE

Permit No. TBD  
A/N 504112

## Equipment Description:

STORAGE TANK NO. 797, FIXED CONE ROOF TANK, 146' DIA. X 41' H., 122,950 BBL SHELL CAPACITY, WITH A CLOSEABLE VENT LINE CONNECTION TO THE TERMINAL'S VAPOR RECOVERY SYSTEM.

## Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THE VENT LINE TO THE VAPOR RECOVERY SYSTEM SHALL REMAIN OPEN WHEN THE TANK IS IN SERVICE EXCEPT THAT THE VENT LINE MAY BE CLOSED WHEN THE TANK IS USED TO STORE THE FOLLOWING COMMODITIES:  
  
DIESEL FUEL (INCLUDING BIODIESEL)  
JET A KEROSENE  
  
[RULE 463, 1303(a)(1)-BACT, 1303(b)(2)-OFFSETS, RULE 1401, 40 CFR 63 SUBPART R]
4. THE OPERATOR SHALL KEEP A RECORD OF ALL PRODUCTS STORED IN THIS TANK. THE RECORD SHALL IDENTIFY EACH PRODUCT AND INCLUDE THROUGHPUT, RIED VAPOR PRESSURE, DATES OF STORAGE, AND STATUS OF THE VENT LINE TO THE VAPOR RECOVERY SYSTEM (OPEN OR CLOSED).  
[RULE 463, 1303(a)(1)-BACT, 1303(b)(2)-OFFSETS, RULE 1401, 40 CFR 63 SUBPART R]
5. THE COMBINED THROUGHPUT FOR TANKS 791 AND 797 SHALL NOT EXCEED 50,740,200 GALLONS IN ANY ONE CALENDAR MONTH. THE MAXIMUM CALENDAR MONTHLY THROUGHPUT FOR PRODUCTS OTHER THAN DIESEL AND JET A KEROSENE SHALL NOT EXCEED:  
  

TANK NO. 791	19,756,800 GALLONS
TANK NO. 797	30, 983, 400 GALLONS

  
[RULE 463, 1303(a)(1)-BACT, 1303(b)(2)-OFFSETS, RULE 1401, 40 CFR 63 SUBPART R]
6. THIS TANK SHALL NOT BE USED TO STORE ORGAINC LIQUIDS WITH A RIED VAPOR PRESSURE GREATER THAN RVP 15 PSI.  
[BACT RULE 1303(B)(2)-OFFSETS]
7. ALL RECORDS REQUIRED BY THE CONDITIONS OF THE IS PERMIT INCLUDING THOSE RECORDS REQUIRED BY RULE 463, SHALL BE MAINTAINED FOR A FIVE YEAR PERIOD AND BE AVAILABLE FOR INSPECTION BY AUTHORIZED DISTRICT PERSONNEL.

[RULE 463]

**Periodic Monitoring: NONE**

**Emissions and Requirements:**

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC:	RULE 463
VOC:	RULE 1149
HAP/TOC:	40 CFR 63 SUBPART R (MAJOR SOURCE)